
## MODEL 4000D





This patented Ductile Iron Ball Valve has been engineered to replace any plug valve, carbon steel ball valve, or gate valve.

Teflori\* is a registered trademark of DuPont.

- 65-45-12 Ductile Iron Body with FDA foodgrade epoxy powder coat.
- Teflon® Fused Solid Stainless Steel Ball
- · Blow-out Proof Stainless Steel Stem
- Reinforced Teflon® Seats
- Face to Face and Flanged Dimensions conform to ANSI Standard B16.10 which exactly match end to end dimensions of carbon steel ball valves, ductile iron gate valves, and plug valves.
- Lockable in Full Open or Closed Positions
- . Mounting Pad for Easy Actuation
- Adjustable Length/Removable Handles to fit into areas of limited space.
- Full Port through 6"

## SPECIFICATIONS:

MSS SP-72

ANSI B16.5 Raised Face

FED. SPEC. WW-V-35


AWWA C507-99 Proof of Design Test ANSI/NSF 61-8 / California Prop. 65

## RATING:

150 psi WSP 300 psi WOG 366° F



	2	2 1/2	3	4	6	8	10
A Face to Face	7	716	8	9	1016	11%	13
B Center of Port to Top	5 1/2	7	7%	8 1/2	13	13	15
C Flange Diameter	6	7	71/2	9	11	131/2	16
D Center of Valve to Handle End	12	13 1/2	13 1/2	151/2	30	30	33
E Port Diameter	2	21/2	3	4	6	6	8
Bolt Holes	4	4	4	8	8	8	12
Weight ibs.	22	36	46	75	131	185	276
CV*	500	750	1245	2500	5470	4150	6700



## SAMPLE SPECIFICATION:

Ball valves shall be of the floating-ball design capable of providing bi-directional, tight shutoff in accordance with MSS SP-72. The valves shall be rated at 150# WSP/300# WOG. Bodies shall be ductile iron per ASTM A538, With ANSI Class 150 raisedface flanges. The interior and exterior of the body shall be epoxy-coated. The ball shall be PTFE infused stainless steel, with a 304 stainless steel blowout-proof stem. The seats and body seals shall be PTFE. The stem seal shall be PTFE, externally adjustable chevron type. Valves shall be equipped with locking handles as standard. If service conditions require, valves may be equipped with 2" square operating nuts, manual gear operators, or pneumatic, electric, or hydraulic actuators. Valves shall be the Series 4000D as manufactured by American Valve, Inc. or as approved by the engineer.